



POLICE HEADQUARTERS { PROVISION SECTION }

J&K SRINAGAR.

Phone/Fax No: 0194-2443031/ 2443032
0191-2459029/2459255(Jammu)

(Sgr)Website:www.jkpolice.gov.in
Email: phqjk@jkpolice.gov.in


Amendment Notice

Pursuant to pre bid conference discussion & queries raised by the intending firms, following amendments are notified in the e.tender notice no 40 of 2018 dated 31.08.2018 floated for supply & installation of Cold storage plants in FSL :-

Serial No	Tender contents	Amended contents/technical specification																																		
Serial 5, Furnishing of EMD	Other Tenderers to furnish EMD of Rs 1,00,000/-	Other tenderers to furnish EMD of Rs 30,000/- instead of Rs 1,00,000/-																																		
Technical specification	<table border="1"> <tr> <td>External Room Dimensions (L X B X)</td> <td>12' x 12' x 9' (EXTERNAL SIZE)</td> </tr> <tr> <td>Desired Room temperature</td> <td>-5 to +4 Deg C</td> </tr> <tr> <td>Segment</td> <td>Human Anatomy</td> </tr> <tr> <td>Pull down time desired</td> <td>24 Hr.</td> </tr> <tr> <td>No of Door openings per day/hour</td> <td>3-4 Openings for 10 Sec Each /Hr</td> </tr> <tr> <td>Wall & Ceiling Insulation and thickness</td> <td>80mm thick Blue Star or alike Cyclopentane Panels with PP/PP Finish. (Eco Friendly)</td> </tr> <tr> <td>Floor insulation and thickness</td> <td>60mm thick PUF Slab (PCC, Kota Stone in customer scope)</td> </tr> <tr> <td>Door type and size</td> <td>Blue Star or alike Cyclopentane Panel Door -34" x78 " clear opening, Swing Door , PP/PP</td> </tr> <tr> <td>No of Doors</td> <td>1 Nos.</td> </tr> <tr> <td>Door Type</td> <td>Hinge Door Flush Type</td> </tr> <tr> <td>Product stacking details</td> <td>In Racks (customer scope)</td> </tr> <tr> <td>Refrigeration unit selected</td> <td>Blue Star make Evaporating Unit & with Matching fully Dressed Blue Star 0 alike Condensing Unit RUAM01214 - 2 NO.s [1 Working + 1 Standby]</td> </tr> <tr> <td>Total Condensing unit Capacity</td> <td>20,000 BTU/h total condensing capacity</td> </tr> <tr> <td>Evaporator Body Material</td> <td>In Stainless steel 304 grade & excellent corrosion Resistance, Improved Air-Throw, Excellent Corrosion Resistance, Inner grooved Cu Tubes, Removable Side Panels, Ext. rotor Driven Fans with low noise levels and conform IP45 Standards</td> </tr> <tr> <td>Refrigerant</td> <td>R-404 (Eco Friendly)</td> </tr> <tr> <td>Power supply</td> <td>230v/1 ph/50Hz</td> </tr> <tr> <td>Power Consumption (Each machine)</td> <td>1.7 KW</td> </tr> </table>	External Room Dimensions (L X B X)	12' x 12' x 9' (EXTERNAL SIZE)	Desired Room temperature	-5 to +4 Deg C	Segment	Human Anatomy	Pull down time desired	24 Hr.	No of Door openings per day/hour	3-4 Openings for 10 Sec Each /Hr	Wall & Ceiling Insulation and thickness	80mm thick Blue Star or alike Cyclopentane Panels with PP/PP Finish. (Eco Friendly)	Floor insulation and thickness	60mm thick PUF Slab (PCC, Kota Stone in customer scope)	Door type and size	Blue Star or alike Cyclopentane Panel Door -34" x78 " clear opening, Swing Door , PP/PP	No of Doors	1 Nos.	Door Type	Hinge Door Flush Type	Product stacking details	In Racks (customer scope)	Refrigeration unit selected	Blue Star make Evaporating Unit & with Matching fully Dressed Blue Star 0 alike Condensing Unit RUAM01214 - 2 NO.s [1 Working + 1 Standby]	Total Condensing unit Capacity	20,000 BTU/h total condensing capacity	Evaporator Body Material	In Stainless steel 304 grade & excellent corrosion Resistance, Improved Air-Throw, Excellent Corrosion Resistance, Inner grooved Cu Tubes, Removable Side Panels, Ext. rotor Driven Fans with low noise levels and conform IP45 Standards	Refrigerant	R-404 (Eco Friendly)	Power supply	230v/1 ph/50Hz	Power Consumption (Each machine)	1.7 KW	<ul style="list-style-type: none"> Approximate Room size in feet (L) 12 X(B) 12 X(H) 9ft Room temperature required Between -5 degree C to +4 degree C with a control tolerance of ± 2 degree or better Door 80 mm thick insulated Flush type door, clean door opening of 34" X 78" Heavy duty cast alloy handles and heavy duty hinges with chrome finish airtight heavy duty sealing gasket below door with a double sweep, Posi-sea closure: cushion closing of door, making it noiseless and firmly shut. Wall Panel:- 80 mm thick PP cyclopentane Puf Panels. Wall to Wall can looking system. There must be corner Panels of 12"x12" to avoid thermal loss and avoid bacteria breeding. Internal and external flushing to be provided. Ceiling Panel-80 mm thick cyclopentane panel with ceiling to ceiling can looking system. Floor-60 mm PUF insulation, with drainage to external drain Each room of vapor –proof two LED lights, should be designed to work at -5 to +4 deg-c Safety release knob to be provided in door from inside Refrigeration Unit: - 02 each capacity 10000 BTU/Hr @ -5 degree C room temp and +35 deg C Ambient Temp (Brand Carrier, Blue State, Diakin or Alike). Indoor Unit:-Evaporator Body to be made of stainless Steel,SS304 Grade Outdoor Unit: - Compressor should Hermetic sealed. Heavy duty air cooled with low noise level and minimal
External Room Dimensions (L X B X)	12' x 12' x 9' (EXTERNAL SIZE)																																			
Desired Room temperature	-5 to +4 Deg C																																			
Segment	Human Anatomy																																			
Pull down time desired	24 Hr.																																			
No of Door openings per day/hour	3-4 Openings for 10 Sec Each /Hr																																			
Wall & Ceiling Insulation and thickness	80mm thick Blue Star or alike Cyclopentane Panels with PP/PP Finish. (Eco Friendly)																																			
Floor insulation and thickness	60mm thick PUF Slab (PCC, Kota Stone in customer scope)																																			
Door type and size	Blue Star or alike Cyclopentane Panel Door -34" x78 " clear opening, Swing Door , PP/PP																																			
No of Doors	1 Nos.																																			
Door Type	Hinge Door Flush Type																																			
Product stacking details	In Racks (customer scope)																																			
Refrigeration unit selected	Blue Star make Evaporating Unit & with Matching fully Dressed Blue Star 0 alike Condensing Unit RUAM01214 - 2 NO.s [1 Working + 1 Standby]																																			
Total Condensing unit Capacity	20,000 BTU/h total condensing capacity																																			
Evaporator Body Material	In Stainless steel 304 grade & excellent corrosion Resistance, Improved Air-Throw, Excellent Corrosion Resistance, Inner grooved Cu Tubes, Removable Side Panels, Ext. rotor Driven Fans with low noise levels and conform IP45 Standards																																			
Refrigerant	R-404 (Eco Friendly)																																			
Power supply	230v/1 ph/50Hz																																			
Power Consumption (Each machine)	1.7 KW																																			
<table border="1"> <thead> <tr> <th colspan="6">BOQ</th> </tr> <tr> <th>Description</th> <th>Qty</th> <th>Basic Rate</th> <th>GST</th> <th>Any other charges which firm intend to charge</th> <th>Total Amount in Rs/-</th> </tr> </thead> <tbody> <tr> <td>Supply of 80mm Prefabricated PUF Panels, Refrigeration Machines along with fitting of Accessories and Installation</td> <td>02 No</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Installation</td> <td>02 No</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		BOQ						Description	Qty	Basic Rate	GST	Any other charges which firm intend to charge	Total Amount in Rs/-	Supply of 80mm Prefabricated PUF Panels, Refrigeration Machines along with fitting of Accessories and Installation	02 No					Installation	02 No															
BOQ																																				
Description	Qty	Basic Rate	GST	Any other charges which firm intend to charge	Total Amount in Rs/-																															
Supply of 80mm Prefabricated PUF Panels, Refrigeration Machines along with fitting of Accessories and Installation	02 No																																			
Installation	02 No																																			
<p>Interconnecting circuit between indoor and outdoor for ref. System should be included in the quoted cost.</p>																																				

	<p style="text-align: center;">CUSTOMER SCOPE</p> <ul style="list-style-type: none"> • Water and Power to be provided free of cost by the department during execution. • Power supply to respective condensing units/ individual control panels with an isolator as installed by the approved supplier to be provided by the department. • Provision of Drain Traps for condensed water at points to be provided by the approved vendor. • Facilities for safe storage of the equipment to be provided by the department. <p>Any other works / items not specifically mentioned in the tender to be provided by the approved supplier</p>	<p>vibration. MOC should be GI powder coated. Filter dryer should be inbuilt.</p> <ul style="list-style-type: none"> • Refrigerant: Eco friendly refrigerant (R 404 etc.) • Control Panel:-Display should have Microprocessor based Digital temperature controller cum Indicator for easy readability. • PVC strip curtain-1 No • Bidder or principal supplier should be in similar business for minimum 5 years (copy should be enclosed to support alongwith technical bid) • Firm should not be blacklisted in any state Govt./institute/semi Government. Only OEM or authorized dealer of the OEM are legible to quote • Sourcing of components from different suppliers will not be permitted & bid will be rejected.
--	--	--


Other contents of the tender shall remain unchanged.


 Mubassir Latifi JKPS
 (AIG Provision/Transport)
 For Director General of Police,
 J&K-Srinagar
 Dated: 20.09.2018

No: - Prov-II /FSL-38/2018-19/ 63852-80

Copy to the:-

23. Principal Secretary to Govt. Home Department J&K Srinagar
24. All ADsGPJ&K
25. All IsGPJ&K
....for favour of information.
26. Director FSL J&K Srinagar for information.
27. DIG CKR Srinagar/DIG Jammu-Kathua& Samba Range Jammu.
28. Director Industries Jammu/Srinagar for information.
29. Chief Accounts officer PHQ J&K Srinagar for information
30. Jt. Director FSL J&K Srinagar for information.
31. Manager Government Press Srinagar / Jammu for publication of amendment notice in Govt Gazette.
32. SSP J&K CID Cell, 11 Harish Chander Mathur Lane Kasturba Gandhi Marg New Delhi-110001 alongwith copy of amendment notice for information intending firms.
33. AIG Communication PHQ J&K Srinagar for information with the request to arrange publication of amendment notice through information department.
 1. In-Charge IT Centre PHQ/In-Charge e-tendering PHQ for placing the e-tender on the website of J&K Police and J&K Govt. Portal.


 Mubassir Latifi JKPS
 (AIG Provision/Transport)
 For Director General of Police,
 J&K-Srinagar